



STRU BUILD CONSULTANTS LLP

Consulting Structural Engineers

Date: 30th June 2022

Building : Acharya Mahapragya Vidyanidhi Foundation (School) building

Address: 32 Dadiseth Agiary Lane, Kalbadevi Road, Mumbai 400002

Sub : Structural stability declaration for the Building under consideration.

TO WHOMSOEVER IT MAY CONCERN

On 30th June 2022, our team of engineer had personally visited the building under subject with a perspective to inspect the structural stability of the building.

Building is RCC framed structured of ground plus four upper floors.

As per available information last structural repair was done four years back.

Following are our technical observations element-wise noticed during visit.

Slab / Floors: No severe cracking or bulging of ceiling/flooring or exposed reinforcement were found. Minor/ hair cracks were observed which seems in plaster only.

Beams: No structural cracks were observed. Doors and windows are free to use, hence beams are not deflected.

Columns: No structural cracks were observed.

Staircase: It was also found in good condition.

Compound wall: Found in good condition.

CONCLUSION: The building seems to be in stable & sound condition as inspected visually and is good for habitation for the intended use.


Qureshi AbdulQayyum

MCGM Reg. No STR/Q/04