

JYOTI FIRE

MAKING A SECURED FUTURE WITH US

JYOTI FIRE SERVICES LLP

Approved Licensed Agency by Maharashtra Fire Services
243, SHREEJI CHAMBERS, 2ND FLOOR, TATA ROAD NO. 2, OPERA HOUSE, MUMBAI - 400 004.
TEL: 022 - 2363 8712 / 2363 8679 / 2352 1735 / 2352 0328
E-mail : jyotifireservicesllp@gmail.com

To,
The Chief Fire Officer,
Mumbai Fire Brigade,
Mumbai

Ref: JFS/MPPS/Form B/023

FORM- B

[Refer Section 3(3) and Rule 4(2)]

Certificate by License Agency of Maharashtra Fire Prevention & Life Safety Measures Act 2006

**Six monthly certificate to be given in every January and July for compliance of the
Fire Prevention and Life Safety Measures.**

CERTIFICATE

Certified that, we have carried out inspection of the fire prevention and life safety measures in the following building or premises namely: -

M/s. MAHAPRAGYA PUBLIC SCHOOL

Address: 32, Dadiseth Agyari Lane, Kalbadevi Road, Mumbai - 400002

We further certify that these installations in above mentioned building is in good repair and efficient condition during the period 1st January to 30th June 2022, as required under Maharashtra Fire Prevention and Life Safety Act – 2006 (Mah. III - 2007).

The Details of the inspection of the installation carried by us are mentioned in the report appended herewith.

Place: Mumbai

Date: 12 July, 2022

SAURIN
RAJENDRAKUMAR
SHETH

Digitally signed by SAURIN
RAJENDRAKUMAR SHETH
Date: 2022.07.12 18:22:56
+05'30'

Signature and Address of the Licensed Agency
For M/S. Jyoti Fire Services LLP
17, Arun Chambers, Ground Floor,
Tardeo Road, Mumbai – 400 034
License No. MFS / LA / RF-237 / RD-231



• FIRE EXTINGUISHERS ISI



• HYDRANT SYSTEM & ACCESSORIES



• KITCHEN FIRE SUPPRESSION SYSTEM



• SIGNAGES & SAFETY EQUIPMENTS



• FIRE ALARM SYSTEMS



• SPRINKLER SYSTEMS

JYOTI FIRE SERVICES LLP

Approved Licensed Agency by Maharashtra Fire Services
243, SHREEJI CHAMBERS, 2ND FLOOR, TATA ROAD NO. 2, OPERA HOUSE, MUMBAI - 400 004.
TEL.: 022 - 2363 8712 / 2363 8679 / 2352 1735 / 2352 0328
E-mail : jyotifireservicesllp@gmail.com

Annexure- B

We have carried out the testing of the fire prevention and life safety measures instruments

Placed at: - MAHAPRAGYA PUBLIC SCHOOL

Address: 32, Dadiseth Agyari Lane, Kalbadevi Road, Mumbai - 400002

We have carried out the testing of the Fire Hydrant & Alarm System is working properly.

Detail of the Fire Fighting Equipment is as under:-

SL NO	Tower Assets	Quantity
1	5 HP Booster Pump on Terrace	01 No.
2	ON / OFF Starer	01 No.
3	Fire Inlet: - 2 way	01 No.
4	Courtyard (Single) Hydrant Point	01 No.
5	Courtyard Hose Box (Single Door)	01 No.
6	Staircase Hydrant Point	09 No.
7	Staircase Hose reel Drum (Fire Hose Reel Pipe is 15 mtr long)	09 No.
8	Staircase Hose Box (Single Door)	09 No.
9	Canvas Hose	10 No.
10	Branch Pipe	01 No.
11	Fire Alarm Panel (cum PA system)	01 No.
12	Smoke Detector	40 Nos.
13	Manual Call Point	10 No.
14	Hooter	10 No.
15	Fire Extinguishers ABC type Cap - 2 kg	03 No.
16	Fire Extinguishers ABC type Cap - 5 kg	05 No.
17	Fire Extinguishers ABC type Cap - 6 kg	01 No.
18	Fire Extinguishers CO ₂ type Cap - 4.5 kgs	01 No.

Note: Alternate power supply not provided.

SAURIN
RAJENDRAKUMAR SHETH

Digitally signed by SAURIN
RAJENDRAKUMAR SHETH
Date: 2022.07.12 18:23:12 +05'30'

Signature and Address of the Licensed Agency

For M/S. Jyoti Fire Services LLP

17, Arun Chambers, Ground Floor,
Tardeo Road, Mumbai - 400 034

License No. MFS / LA / RF-237 / RD-231



- FIRE EXTINGUISHERS ISI
- HYDRANT SYSTEM & ACCESSORIES



- KITCHEN FIRE SUPPRESSION SYSTEM
- SIGNAGES & SAFETY EQUIPMENTS



- FIRE ALARM SYSTEMS
- SPRINKLER SYSTEMS



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
**License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-237 / RD-231

Date: 30.04.2022

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Jyoti Fire Services LLP** having their registration office at **17, Arun Chambers, Next to A.C. Market, Tardeo, Mumbai 400 034** and their contact details are Office Number: 9920733378 and Email ID: jyotifireservices@hotmail.com with PAN registration No. AAPFJ4307E and GST No. 27AAPFJ4307E1ZE to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

M/s. Jyoti Fire Services LLP shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **30.04.2022 to 29.04.2023**

Hatyal
Kiran
Asst Director

Digitally signed
by Hatyal Kiran
Date: 2022.05.07
10:18:18 +05'30'

SAURIN
RAJENDRAKUMAR
SHETH

Digitally signed by SAURIN
RAJENDRAKUMAR SHETH
Date: 2022.05.07 11:28:57
+05'30'

Digital Signature of License Holder

SANTOSH
SHRIDHAR
WARICK

Digitally signed by
SANTOSH
SHRIDHAR WARICK
Date: 2022.05.08
20:03:33 +05'30'

Director
Maharashtra Fire Service

Note:

* in lieu of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.